A–51[™] Incandescent Factory Sealed Luminaires

For Group A and B Locations. Explosionproof

Suitable for use in Wet Locations. UNILETS® for use with Threaded Metal Conduit.

NEC/CEC — For Group A and B: Class I, Division 1 and 2, Groups A , B, C, D Class II, Division 1 and 2, Groups E, F, G Class III

Mounting Hoods

| | Туре | Hub Size (Inches) | Catalog Number |
|-------------------|----------------------------|-------------------|-----------------|
| Pendant | | | |
| | One Hub, | 1/2 | AAP-50 ① |
| | Rigid or Flexible Mounting | 3/4 | AAP-75 ① |
| Ceiling | | | |
| A 10 PM | Four Hubs, | 1/2 | AAC-50 |
| | Three Close-up Plugs | 3/4 | AAC-75 |
| 15° Short Bracket | | | |
| | Two Hubs, | 1/2 | AASB-50 |
| | One Close-up Plug | 3/4 | AASB-75 |

| | Description | Catalog Numbe |
|--|--|---------------|
| Fixture Units | | |
| and the same of th | 60-200 W | AAUA-15 |
| | PS-25 | AAUA-15 |
| and the same | 200-300 W | |
| | PS-30 | AAUA-2 |
| Globe and Ring Assembly | | |
| | 60-200 W (AAUA-15) | AAGLA-15 |
| | 200-300 W (AAUA-2) | AAGLA-2 |
| Aluminum Guards | 22 22 11 12 12 | |
| A P | 60-200 W (AAUA-15) | AAGUA-15 |
| | 200-300 W (AAUA-2) | AAGU-2 |
| Medium Base Lamp Socket | | |
| | 60-200 W (AAUA-15) | AASPA-15 |
| (a) | 200-300 W (AAUA-2) | AASPA-22 |
| Connection Block | | |
| | Fits all A-51 and AA-51 mounting hoods | |

60-300 W

① Group A pendant mount only.



VPT-7